

PUBLIC HEALTH ENGINEERING DEPARTMENT

DISTRICT WATER TESTING LABORATORY, HISAR

Website :- <https://phedharyana.gov.in/>

Memo No:- 24

Date:- 08/01/2024

HC-1040

Subject : Physical / Chemical Examination Report of Water Sample

Sample ID/Classification : HSR/03618/1/2024 / Private	Sample Details	Date & Time
Sender : Aryan Public School27335	Collected By	
Location : , VPO Fransi, Hisar	Collection Date	05/01/2024 at 10:28
Sample Description : Drinking Water	Received at lab	05/01/2024 at 11:51
Latitude / Longitude : 75.599546 / 29.307694	Analysis Start Date	05/01/2024
	Analysis End Date	08/01/2024
	Sample Quantity	2 Ltr.

Test Result (As Per BIS 10500 :2012)

S.No.	Tested Parameter	Result	Requirement (Acceptable Limit)	Permissible Lmt. (In the Absence of Alternate Source)	Protocol Used
1	Total Dissolved Solids @ 180°C ± 2°C	250	500 mg/lt.	2000 mg/lt.	APHA 24th Edition -2540 C
2	Total Hardness as CaCO ₃	146.3	200 mg/lt.	600 mg/lt.	APHA 24th Edition -2340 C
3	Calcium as Ca	33.02	75 mg/lt.	200 mg/lt.	APHA 24th Edition-3500-Ca B
4	Magnesium as Mg	15.52	30 mg/lt.	100 mg/lt.	APHA 24th Edition -3500 Mg B
5	Iron as Fe	0.01	1.0 mg/lt.	1.0 mg/lt.	USEPA
6	Chloride as Cl	36.86	250 mg/lt.	1000 mg/lt.	APHA 24th Edition -4500 Cl-B
7	Sulphate as So ₄	38	200 mg/lt.	400 mg/lt.	USEPA / APHA 24th -4500 SO ₄ -E
8	Fluoride as F	0.23	1.0 mg/lt.	1.5 mg/lt.	APHA 24th Edition-4500F C/
9	Nitrate as No ₃	0.79	45 mg/lt.	45 mg/lt.	APHA 24th Edition -4500 NO ₃ D
10	pH @ 25°C	6.82	6.5 - 8.5	6.5 - 8.5	APHA 24th Edition 4500-H+ B
11	Total Alkalinity	75.6	200 mg/lt.	600 mg/lt.	APHA 24th Edition -2320 B

Remarks :-

- * The Results Given above are related to the sample as received and tested in PHED HISAR Lab.
- * The test report can't be regenerated in whole or part there of without written permission of Competent Authority.
- * The test report can't be used for any publicity or any legal purpose.
- * Reliability of water sample sample lies with sender/collector of water sample.
- * To check the sample report online Scan the QR Code below.
- * The test samples meant for chemical analysis will be disposed off after 15 days from the data of issue of test report unless until specifically requested by the customer for retaining over a longer period.

Water Sample has been found "CONFORMING" to Limits set in BIS10500:2012 for the tested parameters. Based on the tested parameters,the water sample is found "POTABLE"



Sample analyzed by :

jaipal

Rajeev

RAJEEV KUMAR ,CHEMIST
DISTRICT WATER TESTING LABORATORY,HISAR
email:-chemist.hisar@phedharyana.gov.in



O/o Civil Surgeon , Hisar

Mail-Id:- dhs.cshsr@hry.nic.in


Letter No. HSR/DHO/HI/2024/ 37

Dated: 05-03-2024

OFFICE OF CIVIL SURGEON HISAR

Hygienic and Sanitation certificate

Certified that the condition of the building of
ARYAN PUBLIC SCHOOL VILLAGE: Pragansi, HISAR
..... with regards to the Sanitation and Hygienic
condition is satisfactory for the one year w.e.f date of issuing.


5/3/24.
Dy Civil Surgeon(Health)

For Civil Surgeon, Hisar
5/3/24